

GAUHATI UNIVERSITY

GUWAHATI - 14

Pre-bid meeting held on 27.02.17 on NIT No. T/16-17/444 dtd. 09.02.17 for "Design, manufacture, supply, installation, testing & commissioning of outdoor sports lighting for the Gauhati University"

Name of Bidder Present:

1. **Mr. Hemanta Medhi**
Senior Manager
Bajaj Electrical Ltd.
2. **Mr. Vinu Philipose**
Asst. General Manager
Lighting Technologies Pvt. Ltd, Bangalore
3. **Mr. Rajesh Chetri**
Manager Sales
NEZONE GROUP, Guwahati.
4. **Mr. Biswajit Dutta**
Manager
Havells India Ltd. Guwahati
5. **Mr. Dipankar Bora**
ADRO TRADING AND ASSOCIATES

Minutes of Meeting

1. It is confirmed that the minimum average horizontal illuminance shall be 115 Lux as mentioned in the NIT Cl. No.1.2.2 B page-25. Provision for installation of 30% extra light fittings per mast shall be kept in luminaire frame along with similar provision in the electrical distribution board inside the masts at the base.
2. The High mast shall be fixed type with ladder at the back side for climbing by the workmen (Ref. Cl. No. 3.11.5 ; page-44)
3. Minimum CRI shall be 70 instead of 80 (Ref. Cl. No. 1.2.2 B; page 25)
4. Light fittings shall be die cast aluminium.
5. Electrical Contractor's License shall have to be submitted along with the techno-commercial bids. In case the bidder does not possess the Electrical Contractor's License, he may engage an electrical sub-contractor having valid the Electrical Contractor's License for electrical part of the contract. In that case, an undertaking shall be enclosed by the bidder stating clearly that in case contract is awarded ,he/ they would engage the particular electrical contractor (name & address shall be written) as sub-contractor for electrical part of the contract. Consent from the concerned electrical sub-contractor in the form of an undertaking shall also be enclosed. In such case, a copy of the valid Electrical Contractor's License of the concerned sub contractor shall have to be enclosed.
6. It is confirmed that Feeder Pillars shall be of IP 65 ((Ref. Item No. 9, Price Bid)
7. The enclosure for feeder pillars shall be 1.66 mm thick as specified in the BOQ (Ref. Item No.9)
8. Feeder pillars shall be installed on pedestal as specified in clause 3.4.1 of the Technical Specification (page-37)
9. G.I. earth pipes shall be 4.5m long as specified in item no. 7 of the BOQ.
10. Electrical Distribution Boards shall be as specified in the BOQ (Ref. Item No.9)
11. S.L.D. shall be provided after award of contract to the successful bidder.
12. A copy of the price bid as submitted without the price, shall be enclosed along with the techno-commercial bids.

Sd/-
Dharmeswar Kalita
Assistant University Engineer(E)

Sd/-
Amarendra Goswami
Member, Technical Committee

Sd/-
Sanjib Boruah
Superintending Engineer,i/c